



Pollutant Monitoring Results - Wet Weather Discharge

Licence Name: SUEZ	Environmental Protection Licence Number: 12889	Facility Address: 1725 Elizabeth Drive, Kemps Creek 2171
Period: Sep-16	A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/prpoeapp/	

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZ's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
2/09/2017	1	1	Ammonia	Special frequency 1	1.94	1.94	1.94	1.94	mg/l	0.9	Y	
2/09/2017	1	1	Biochemical oxygen demand	Special frequency 1	3	3	3	3	mg/l	NA	N	
2/09/2017	1	1	Conductivity	Special frequency 1	2930	2930	2930	2930	µS/cm	NA	N	
2/09/2017	1	1	Oil and Grease	Special frequency 1	<5	<5	<5	<5	mg/l	NA	N	
2/09/2017	1	1	pH	Special frequency 1	7.63	7.63	7.63	7.63	pH	6.5-8.5	N	
2/09/2017	1	1	Total organic carbon	Special frequency 1	37	37	37	37	mg/l	NA	N	
2/09/2017	1	1	Total suspended solids	Special frequency 1	45	45	45	45	mg/l	50	N	

