

EPA License Number: 4458 (Updated)

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 1 Monthly Summary

Note: does not include any monitoring conducted prior to 31 March 2012.

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Apr-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2.59	4.76	9.46	50
	pH	pH	Daily during any discharge	4	7.88	8.20	8.5	6.5-8.5
May-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2.73	3.95	5.16	50
	pH	pH	Daily during any discharge	2	7.94	8.09	8.24	6.5-8.5
Jun-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	7.25	20	50
	pH	pH	Daily during any discharge	4	7.39	7.74	7.96	6.5-8.5
Jul-12	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	4	4	4	50
	pH	pH	Daily during any discharge	1	7.27	7.27	7.27	6.5-8.5
Aug-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	2	2	50
	pH	pH	Daily during any discharge	2	7.45	7.71	7.97	6.5-8.5
Sep-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4	7	50

	pH	pH	Daily during any discharge	2	7.55	7.66	7.77	6.5-8.5
Oct-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	19.25	37	50
	pH	pH	Daily during any discharge	4	6.67	7.24	7.66	6.5-8.5
Nov-12	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	4.3	6	50
	pH	pH	Daily during any discharge	3	7.69	7.76	7.79	6.5-8.5
Dec-12	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	5	50
	pH	pH	Daily during any discharge	3	7.25	8.0	8.48	6.5-8.5
Jan-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	8.17	8.3	8.35	6.5-8.5
Feb-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	pH	pH	Daily during any discharge	2	8.45	8.48	8.5	6.5-8.5
Mar-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	9.0	22	50
	pH	pH	Daily during any discharge	3	8.28	8.36	8.45	6.5-8.5
Apr-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	6.0	10	50
	pH	pH	Daily during any discharge	3	7.56	8.01	8.36	6.5-8.5
May-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	5.0	8	50
	pH	pH	Daily during any discharge	3	7.64	7.78	7.96	6.5-8.5
Jun-13	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	5.3	10	50

	pH	pH	Daily during any discharge	5	7.67	7.99	8.42	6.5-8.5
Jul-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.17	8.30	8.43	6.5-8.5
Aug-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	4	5.0	6	50
	pH	pH	Daily during any discharge	2	7.64	7.83	8.02	6.5-8.5
Sep-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	0.5	2.2	5	50
	pH	pH	Daily during any discharge	3	7.81	8.08	8.45	6.5-8.5
Oct-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	5	5.5	6	50
	pH	pH	Daily during any discharge	2	7.61	7.69	7.76	6.5-8.5
Nov-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	7	25.0	38	50
	pH	pH	Daily during any discharge	3	7.68	8.19	8.47	6.5-8.5
Dec-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	5.0	10	50
	pH	pH	Daily during any discharge	3	6.81	7.60	8.35	6.5-8.5
Jan-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.0	3	50
	pH	pH	Daily during any discharge	3	7.96	8.16	8.32	6.5-8.5
Feb-14	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	3.2	7	50
	pH	pH	Daily during any discharge	5	6.71	7.53	8.48	6.5-8.5
Mar-14	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	3.0	6	50

	pH	pH	Daily during any discharge	5	6.64	7.29	7.93	6.5-8.5
Apr-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	1	3.7	11	50
	pH	pH	Daily during any discharge	6	6.95	7.48	8.19	6.5-8.5
May-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.5	1.8	6	50
	pH	pH	Daily during any discharge	6	6.57	7.34	7.67	6.5-8.5
Jun-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.5	1.3	3	50
	pH	pH	Daily during any discharge	6	7.18	7.57	7.91	6.5-8.5
Jul-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.0	1	50
	pH	pH	Daily during any discharge	3	7.58	8.00	8.37	6.5-8.5
Aug-14	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	8.5	23	50
	pH	pH	Daily during any discharge	4	6.62	7.97	8.47	6.5-8.5
Sep-14	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	5	5.0	5	50
	pH	pH	Daily during any discharge	1	7.92	7.92	7.92	6.5-8.5
Oct-14	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	28	28.0	28	50
	pH	pH	Daily during any discharge	1	6.99	6.99	6.99	6.5-8.5
Nov-14	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	pH	pH	Daily during any discharge	2	6.69	7.41	8.12	6.5-8.5
Dec-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	18.7	28	50

	pH	pH	Daily during any discharge	3	6.56	7.42	8.23	6.5-8.5
Jan-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	0.5	4.5	10	50
	pH	pH	Daily during any discharge	3	7.37	7.83	8.09	6.5-8.5
Feb-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.1	8.10	8.1	6.5-8.5
Mar-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	8.25	8.31	8.37	6.5-8.5
Apr-15	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	3	12.8	23	50
	pH	pH	Daily during any discharge	5	8.03	8.33	8.43	6.5-8.5
May-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	6.66	7.29	7.92	6.5-8.5
Jun-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	6	8	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	5.7	11	50
	pH	pH	Daily during any discharge	3	7.52	8.03	8.34	6.5-8.5
Jul-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	7.96	7.96	7.96	6.5-8.5
Aug-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	10.0	19	50
	pH	pH	Daily during any discharge	2	7.37	7.76	8.14	6.5-8.5
Sep-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50

	pH	pH	Daily during any discharge	2	8.05	8.26	8.47	6.5-8.5
Oct-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	8.5	12	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	5.7	8	50
	pH	pH	Daily during any discharge	3	7.22	7.68	7.97	6.5-8.5
Nov-15	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	8.0	26	50
	pH	pH	Daily during any discharge	4	8.42	8.44	8.46	6.5-8.5
Dec-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.3	5.5	50
	pH	pH	Daily during any discharge	2	7.01	7.69	8.37	6.5-8.5
Jan-16	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	4.8	10	50
	pH	pH	Daily during any discharge	4	7.90	8.04	8.25	6.5-8.5
Feb-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	38.5	72	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	5.5	8	50
	pH	pH	Daily during any discharge	2	7.91	8.04	8.16	6.5-8.5
Mar-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	1	1.0	1	50
	pH	pH	Daily during any discharge	1	8.04	8.04	8.04	6.5-8.5
Apr-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	8.01	8.07	8.12	6.5-8.5
May-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	7.23	7.56	7.89	6.5-8.5
Jun-16	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	8.4	27	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	15.3	27	50

	pH	pH	Daily during any discharge	4	7.09	7.68	8.17	6.5-8.5
Jul-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	4.5	7	50
	pH	pH	Daily during any discharge	2	7.90	8.04	8.17	6.5-8.5
Aug-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.35	8.35	6.5-8.5
Sep-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	8.23	8.23	8.23	6.5-8.5
Oct-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.37	8.37	8.37	6.5-8.5
Nov-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4.5	8	50
	pH	pH	Daily during any discharge	2	8.25	8.27	8.29	6.5-8.5
Dec-16	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	4.0	6	50
	pH	pH	Daily during any discharge	3	7.46	7.95	8.22	6.5-8.5
Jan-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.36	8.36	6.5-8.5
Feb-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	9.0	17	50
	pH	pH	Daily during any discharge	2	7.76	8.06	8.35	6.5-8.5
Mar-17	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	20.8	38	50

	pH	pH	Daily during any discharge	4	7.78	8.01	8.29	6.5-8.5
Apr-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	6.5	12	50
	pH	pH	Daily during any discharge	2	7.42	7.59	7.75	6.5-8.5
May-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	7.48	7.85	8.21	6.5-8.5
Jun-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	5	6.0	7	50
	pH	pH	Daily during any discharge	2	7.77	8.06	8.35	6.5-8.5
Jul-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	3.0	4	50
	pH	pH	Daily during any discharge	2	8.17	8.33	8.49	6.5-8.5
Aug-17	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.5	2	50
	pH	pH	Daily during any discharge	3	8.09	8.22	8.29	6.5-8.5
Sep-17	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.47	8.47	8.47	6.5-8.5
Oct-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2.5	4.0	5.5	50
	pH	pH	Daily during any discharge	2	7.70	8.07	8.44	6.5-8.5
Nov-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	8.11	8.14	8.16	6.5-8.5
Dec-17	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.0	1	50

	pH	pH	Daily during any discharge	3	7.76	8.08	8.26	6.5-8.5
--	-----------	----	----------------------------	---	------	------	------	---------

Jan-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.5	2.5	50
	pH	pH	Daily during any discharge	3	7.89	8.00	8.16	6.5-8.5

Feb-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.8	6.5	50
	pH	pH	Daily during any discharge	2	7.56	7.86	8.16	6.5-8.5

Mar-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.4	4	50
	pH	pH	Daily during any discharge	4	7.33	7.91	8.29	6.5-8.5

Apr-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1.2	2.2	4	50
	pH	pH	Daily during any discharge	4	8.03	8.27	8.46	6.5-8.5

May-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.8	3	50
	pH	pH	Daily during any discharge	3	8.02	8.24	8.43	6.5-8.5

Jun-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	0.56	3.8	7.8	50
	pH	pH	Daily during any discharge	4	8.00	8.18	8.35	6.5-8.5

Jul-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	7.66	8.07	8.48	6.5-8.5

Aug-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.0	5	50
	pH	pH	Daily during any discharge	4	7.66	7.95	8.18	6.5-8.5

Sep-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50

	pH	pH	Daily during any discharge	3	7.94	7.99	8.06	6.5-8.5
Oct-18	Oil and Grease	milligrams per litre	Daily during any discharge	10	<5	5.60	11	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	10	1	8.5	44	50
	pH	pH	Daily during any discharge	10	7.36	8.14	8.47	6.5-8.5
Nov-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	4.3	8	50
	pH	pH	Daily during any discharge	4	7.77	8.17	8.47	6.5-8.5
Dec-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	5	11.0	20	50
	pH	pH	Daily during any discharge	3	6.83	7.86	8.40	6.5-8.5
Jan-19	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	5.4	16	50
	pH	pH	Daily during any discharge	4	7.14	7.96	8.43	6.5-8.5
Feb-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	8.02	8.30	8.47	6.5-8.5
Mar-19	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	14.3	23	50
	pH	pH	Daily during any discharge	4	7.86	8.12	8.32	6.5-8.5
Apr-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	7.91	8.10	8.46	6.5-8.5

EPA License Number: 4458

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW1 2164

POINT 1 Obtained Data

Note: does not include any monitoring conducted prior to 31 March 2012.

Date Sampled	DGT Sample No.	Volume Discharged (kL)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	pH (pH)	Date Obatined	Date Published
03-Apr-12	DGT SW1 382	4000	<5	4	8.5	26-Apr-12	5-Jul-12
17-Apr-12	DGT SW1 383	4000	<5	2.59	8.26	26-Apr-12	5-Jul-12
18-Apr-12	DGT SW1 384	4500	<5	9.46	7.88	31-May-12	5-Jul-12
26-Apr-12	DGT SW1 385	4000	<5	3	8.17	31-May-12	5-Jul-12
11-May-12	DGT SW1 386	4000	<5	5.16	7.94	31-May-12	5-Jul-12
23-May-12	DGT SW1 387	4000	<5	2.73	8.24	31-May-12	5-Jul-12
01-Jun-12	DGT SW1 388	3500	<5	1	7.96	13-Jun-12	5-Jul-12
06-Jun-12	DGT SW1 389	3000	<5	7	7.39	13-Jun-12	5-Jul-12
12-Jun-12	DGT SW1 390	4500	<5	20	7.69	20-Jun-12	5-Jul-12
28-Jun-12	DGT SW1 391	3500	<5	1	7.93	5-Jul-12	5-Jul-12
11-Jul-12	DGT SW1 392	3000	<5	4	7.27	2-Aug-12	2-Aug-12
10-Aug-12	DGT SW1 393	4000	<5	2	7.97	16-Aug-12	16-Aug-12
27-Aug-12	DGT SW1 394	4000	<5	2	7.45	3-Sep-12	3-Sep-12
11-Sep-12	DGT SW1 395	4000	<5	7	7.55	25-Sep-12	25-Sep-12
25-Sep-12	DGT SW1 396	3500	<5	1	7.77	3-Oct-12	8-Oct-12
10-Oct-12	DGT SW1 397	3500	<5	2	7.66	17-Oct-12	22-Oct-12
15-Oct-12	DGT SW1 398	3500	<5	19	7.31	22-Oct-12	22-Oct-12
22-Oct-12	DGT SW1 399	2000	<5	19	7.31	30-Oct-12	30-Oct-12
26-Oct-10	DGT SW1 400	2000	<5	37	6.67	31-Oct-12	31-Oct-12
07-Nov-12	DGT SW1 401	4000	<5	4	7.79	13-Nov-12	13-Nov-12
15-Nov-12	DGT SW1 402	2500	<5	6	7.69	23-Nov-12	23-Nov-12
26-Nov-12	DGT SW1 403	3500	<5	3	7.79	4-Dec-12	4-Dec-12

06-Dec-12	DGT SW1 404	3000	<5	1	7.25	13-Dec-12	13-Dec-12
17-Dec-12	DGT SW1 405	3500	<5	1	8.48	21-Dec-12	21-Dec-12
27-Dec-12	DGT SW1 406	4000	<5	5	8.41	9-Jan-13	9-Jan-13
10-Jan-13	DGT SW1 407	4000	<5	1	8.17	17-Jan-13	17-Jan-13
22-Jan-13	DGT SW1 408	3000	<5	2	8.35	30-Jan-13	30-Jan-13
04-Feb-13	DGT SW1 409	4000	<5	5	8.5	12-Feb-13	13-Feb-13
12-Feb-13	DGT SW1 410	3000	<5	3	8.45	19-Feb-13	19-Feb-13
01-Mar-13	DGT SW1 411	4000	<5	22	8.45	11-Mar-13	11-Mar-13
07-Mar-13	DGT SW1 412	2500	<5	4	8.28	13-Mar-13	13-Mar-13
22-Mar-13	DGT SW1 413	3000	<5	1	8.35	4-Apr-13	4-Apr-13
08-Apr-13	DGT SW1 414	4000	<5	5	8.11	15-Apr-13	15-Apr-13
19-Apr-13	DGT SW1 415	3500	<5	3	8.36	29-Apr-13	29-Apr-13
24-Apr-13	DGT SW1 416	3200	<5	10	7.56	2-May-13	3-May-13
07-May-13	DGT SW1 417	3000	<5	3	7.73	15-May-13	16-May-13
21-May-13	DGT SW1 418	3500	<5	4	7.96	30-May-13	3-Jun-13
27-May-13	DGT SW1 419	4000	<5	8	7.64	3-Jun-13	3-Jun-13
05-Jun-13	DGT SW1 420	3500	<5	8.5	7.67	14-Jun-13	14-Jun-13
17-Jun-13	DGT SW1 421	3500	<5	2	8.05	25-Jun-13	26-Jun-13
19-Jun-13	DGT SW1 422	1500	<5	1	7.90	27-Jun-13	27-Jun-13
24-Jun-13	DGT SW1 423	3000	<5	10	8.42	1-Jul-13	2-Jul-13
26-Jun-13	DGT SW1 424	3500	<5	5	7.89	3-Jul-13	4-Jul-13
08-Jul-13	DGT SW1 425	3000	<5	3	8.43	16-Jul-13	16-Jul-13
24-Jul-13	DGT SW1 426	3000	<5	1	8.17	1-Aug-13	2-Aug-13
08-Aug-13	DGT SW1 427	3000	<5	6	8.02	15-Aug-13	15-Aug-13
26-Aug-13	DGT SW1 428	3500	<5	4	7.64	5-Sep-13	5-Sep-13
09-Sep-13	DGT SW1 429	3500	<5	1	7.97	17-Sep-13	18-Sep-13
18-Sep-13	DGT SW1 430	4000	<5	5	8.45	26-Sep-13	27-Sep-13
28-Sep-13	DGT SW1 431	3500	<5	0.5	7.81	8-Oct-13	8-Oct-13
10-Oct-13	DGT SW1 432	3000	<5	6	7.61	21-Oct-13	21-Oct-13
24-Oct-13	DGT SW1 433	3500	<5	5	7.76	1-Nov-13	1-Nov-13
11-Nov-13	DGT SW1 434	3500	<5	30	8.47	19-Nov-11	20-Nov-13
19-Nov-13	DGT SW1 435	4000	<5	38	8.43	26-Nov-13	27-Nov-13
27-Nov-13	DGT SW1 436	2500	<5	7	7.68	4-Dec-13	4-Dec-13

06-Dec-13	DGT SW1 437	3000	<5	10	7.63	16-Dec-13	17-Dec-13
17-Dec-13	DGT SW1 438	2500	<5	2	8.35	9-Jan-13	9-Jan-13
28-Dec-13	DGT SW1 439	3500	<5	3	6.81	16-Jan-14	20-Jan-14
08-Jan-13	DGT SW1 440	3500	<5	3	8.32	16-Jan-14	20-Jan-14
21-Jan-14	DGT SW1 441	4000	<5	2	7.96	29-Jan-14	29-Jan-14
29-Jan-14	DGT SW1 442	4000	<5	1	8.21	5-Feb-14	6-Feb-14
06-Feb-14	DGT SW1 443	4000	<5	1	6.95	14-Feb-14	26-Feb-14
13-Feb-14	DGT SW1 444	3000	<5	1	8.48	25-Feb-14	26-Feb-14
18-Feb-14	DGT SW1 445	3500	<5	7	6.71	25-Feb-14	26-Feb-14
24-Feb-14	DGT SW1 446	4000	<5	4	7.67	3-Mar-14	3-Mar-14
28-Feb-14	DGT SW1 447	2500	<5	3	7.85	7-Mar-14	10-Mar-14
03-Mar-14	DGT SW1 448	4000	<5	6	7.93	11-Mar-14	11-Mar-14
10-Mar-14	DGT SW1 449	4500	<5	2	7.57	18-Mar-14	19-Mar-14
17-Mar-14	DGT SW1 450	4000	<5	1	7.41	1-Apr-14	15-Apr-14
24-Mar-14	DGT SW1 451	4000	<5	1	6.91	1-Apr-14	15-Apr-14
31-Mar-14	DGT SW1 452	4000	<5	5	6.64	10-Apr-14	15-Apr-14
03-Apr-14	DGT SW1 453	2000	<5	2.5	7.42	10-Apr-14	15-Apr-14
08-Apr-14	DGT SW1 454	4000	<5	1.6	6.95	16-Apr-14	16-Apr-14
11-Apr-14	DGT SW1 455	4000	<5	11	7.7	28-Apr-14	28-Apr-14
15-Apr-14	DGT SW1 456	3500	<5	5	7.06	28-Apr-14	28-Apr-14
22-Apr-14	DGT SW1 457	4500	<5	1	7.54	29-Apr-14	30-Apr-14
27-Apr-14	DGT SW1 458	4500	<5	1	8.19	6-May-14	7-May-14
02-May-14	DGT SW1 459	4500	<5	1	7.09	9-May-14	12-May-14
07-May-14	DGT SW1 460	4500	<5	1	6.57	21-May-14	26-May-14
12-May-14	DGT SW1 461	4500	<5	0.5	7.47	21-May-14	26-May-14
16-May-14	DGT SW1 462	4500	<5	1	7.57	3-Jun-14	5-Jun-14
21-May-14	DGT SW1 463	3000	<5	6	7.67	3-Jun-14	5-Jun-14
27-May-14	DGT SW1 464	2000	<5	1	7.65	3-Jun-14	5-Jun-14
02-Jun-14	DGT SW1 465	200	<5	2	7.42	20-Jun-14	20-Jun-14
03-Jun-14	DGT SW1 466	4000	<5	1	7.41	20-Jun-14	20-Jun-14
11-Jun-14	DGT SW1 467	2000	<5	3	7.69	20-Jun-14	20-Jun-14
20-Jun-14	DGT SW1 468	4000	<5	0.5	7.18	1-Jul-14	1-Jul-14
25-Jun-14	DGT SW1 469	4000	<5	0.5	7.91	3-Jul-14	7-Jul-14

30-Jun-14	DGT SW1 470	4000	<5	0.5	7.8	8-Jul-14	9-Jul-14
10-Jul-14	DGT SW1 471	3500	<5	1	8.06	23-Jul-14	24-Jul-14
18-Jul-14	DGT SW1 472	3000	<5	1	7.58	28-Jul-14	28-Jul-14
29-Jul-14	DGT SW1 473	3500	<5	1	8.37	4-Aug-14	5-Aug-14
06-Aug-14	DGT SW1 474	3500	<5	1	8.44	20-Aug-14	21-Aug-14
13-Aug-14	DGT SW1 475	4000	<5	2	8.35	20-Aug-14	21-Aug-14
18-Aug-14	DGT SW1 476	4000	<5	23	8.47	26-Aug-14	27-Aug-14
28-Aug-14	DGT SW1 477	3500	<5	8	6.62	4-Sep-14	5-Sep-14
24-Sep-14	DGT SW1 478	3000	<5	5	7.92	3-Oct-14	7-Oct-14
15-Oct-14	DGT SW1 479	4000	<5	28	6.99	29-Oct-14	30-Oct-14
11-Nov-14	DGT SW1 480	3500	<5	5	6.69	19-Nov-14	21-Nov-14
26-Nov-14	DGT SW1 481	4000	<5	3	8.12	4-Dec-14	4-Dec-14
04-Dec-14	DGT SW1 482	4000	<5	28	6.56	11-Dec-14	12-Dec-14
08-Dec-14	DGT SW1 483	4000	<5	26	7.46	16-Dec-14	16-Dec-14
18-Dec-14	DGT SW1 484	2000	<5	2	8.23	5-Jan-15	5-Jan-15
08-Jan-15	DGT SW1 485	2000	<5	0.5	8.04	19-Jan-15	20-Jan-15
12-Jan-15	DGT SW1 486	4000	<5	10	7.37	4-Feb-15	5-Feb-15
27-Jan-15	DGT SW1 487	2000	<5	3	8.09	4-Feb-15	5-Feb-15
09-Feb-15	DGT SW1 488	4000	<5	2	8.1	17-Feb-15	24-Feb-15
04-Mar-15	DGT SW1 489	4000	<5	3	8.25	11-Mar-15	12-Mar-15
20-Mar-15	DGT SW1 490	1500	<5	4	8.37	26-Mar-15	27-Mar-15
01-Apr-15	DGT SW1 491	4000	<5	4	8.42	10-Apr-15	16-Apr-15
17-Apr-15	DGT SW1 492	4000	<5	3	8.38	24-Apr-15	24-Apr-15
21-Apr-15	DGT SW1 493	4000	<5	21	8.43	1-May-15	1-May-15
22-Apr-15	DGT SW1 494	4000	<5	23	8.03	1-May-15	1-May-15
29-Apr-15	DGT SW1 495	4000	<5	13	8.39	6-May-15	7-May-15
11-May-15	DGT SW1 496	4000	<5	3	6.66	18-May-15	18-May-15
29-May-15	DGT SW1 497	3500	<5	4	7.92	4-Jun-15	5-Jun-15
17-Jun-15	DGT SW1 498	4000	<5	5	8.23	25-Jun-15	25-Jun-15
23-Jun-15	DGT SW1 499	3500	8	11	7.52	2-Jul-15	3-Jul-15
26-Jun-15	DGT SW1 500	3000	<5	1	8.34	2-Jul-15	3-Jul-15
20-Jul-15	DGT SW1 501	4000	<5	6	7.96	27-Jul-15	29-Jul-15
12-Aug-15	DGT SW1 502	4000	<5	1	8.14	20-Aug-15	21-Aug-15

25-Aug-15	DGT SW1 503	4000	<5	19	7.37	1-Sep-15	4-Sep-15
07-Sep-15	DGT SW1 504	4000	<5	3	8.47	15-Sep-15	16-Sep-15
21-Sep-15	DGT SW1 505	4000	<5	1	8.05	2-Oct-15	6-Oct-15
06-Oct-15	DGT SW1 506	4000	<5	6	7.84	14-Oct-15	14-Oct-15
19-Oct-15	DGT SW1 507	4000	<5	8	7.97	26-Oct-15	26-Oct-15
26-Oct-15	DGT SW1 508	3500	12	3	7.22	04-Nov-15	04-Nov-15
02-Nov-15	DGT SW1 509	4000	<5	2	8.45	13-Nov-15	17-Nov-15
13-Nov-15	DGT SW1 510	4000	10	26	8.42	23-Nov-15	24-Nov-15
20-Nov-15	DGT SW1 511	4000	<5	3	8.46	27-Nov-15	27-Nov-15
30-Nov-15	DGT SW1 512	4000	<5	1	8.42	18-Dec-15	31-Dec-15
10-Dec-15	DGT SW1 513	3500	<5	1	8.37	18-Dec-15	31-Dec-15
22-Dec-15	DGT SW1 514	4000	<5	5.5	7.01	14-Jan-16	15-Jan-16
04-Jan-16	DGT SW1 515	4000	<5	7	8.10	14-Jan-16	15-Jan-16
06-Jan-16	DGT SW1 516	3000	<5	10	8.25	14-Jan-16	15-Jan-16
18-Jan-16	DGT SW1 517	3500	<5	1	7.92	25-Jan-16	27-Jan-16
27-Jan-16	DGT SW1 518	3500	5	1	7.9	03-Feb-15	08-Feb-15
05-Feb-16	DGT SW1 519	3000	<5	8	7.91	12-Feb-16	15-Feb-16
22-Feb-16	DGT SW1 520	3000	72	3	8.16	08-Mar-16	10-Mar-16
13-Mar-16	DGT SW1 521	3500	<5	1	8.04	23-Mar-16	14-Apr-16
06-Apr-16	DGT SW1 522	3500	<5	1	8.12	12-Apr-16	14-Apr-16
21-Apr-16	DGT SW1 523	3500	<5	1	8.01	13-May-16	16-May-16
06-May-16	DGT SW1 524	3000	<5	1	7.23	13-May-16	16-May-16
24-May-16	DGT SW1 525	3500	<5	1	7.89	16-Jun-16	17-Jun-16
05-Jun-16	DGT SW1 526	4000	27	27	7.09	16-Jun-16	17-Jun-16
05-Jun-16	DGT SW1 527	2800	<5	27	7.56	16-Jun-16	17-Jun-16

Sample Potentially Contaminated.No visible Oil&Grease during discharge. Not consistant with past and present results

Thunderstorms in Sydney, emergency discharges to prevent flooding. Not representative Sample

17-Jun-16	DGT SW1 528	3500	<5	6	7.88	06-Jul-16	13-Jul-16
29-Jun-16	DGT SW1 529	4000	<5	1	8.17	06-Jul-16	13-Jul-16
15-Jul-16	DGT SW1 530	4000	<5	7	8.17	29-Jul-16	03-Aug-16
26-Jul-16	DGT SW1 531	4000	<5	2	7.9	29-Jul-16	03-Aug-16
12-Aug-16	DGT SW1 532	4000	<5	3	8.35	22-Aug-16	24-Aug-16
25-Aug-16	DGT SW1 533	4000	<5	1	8.35	01-Sep-16	09-Sep-16
14-Sep-16	DGT SW1 534	4000	<5	6	8.23	21-Sep-16	23-Sep-16
13-Oct-16	DGT SW1 535	4000	<5	2	8.37	21-Oct-16	31-Oct-16
02-Nov-16	DGT SW1 536	4000	<5	8	8.29	09-Nov-16	10-Nov-16
21-Nov-16	DGT SW1 537	3500	<5	1	8.25	28-Nov-16	29-Nov-16
05-Dec-16	DGT SW1 538	3500	<5	2	8.22	14-Dec-16	05-Jan-17
16-Dec-16	DGT SW1 539	4000	<5	6	8.17	16-Jan-17	17-Jan-17
29-Dec-16	DGT SW1 540	2400	<5	4	7.46	20-Jan-17	23-Jan-17
10-Jan-17	DGT SW1 541	2500	<5	1	8.36	20-Jan-17	20-Jan-17
30-Jan-17	DGT SW1 542	4000	<5	3	8.35	13-Feb-17	13-Feb-17
14-Feb-17	DGT SW1 543	4000	<5	1	8.35	24-Feb-17	24-Feb-17
27-Feb-17	DGT SW1 544	4000	<5	17	7.76	08-Mar-17	09-Mar-17
02-Mar-17	DGT SW1 545	3500	<5	38	8.29	08-Mar-17	09-Mar-17
14-Mar-17	DGT SW1 546	3500	<5	8	7.87	20-Mar-17	21-Mar-17
18-Mar-17	DGT SW1 547	3000	<5	36.3	8.11	27-Mar-17	27-Mar-17
29-Mar-17	DGT SW1 548	4000	<5	1	7.78	06-Apr-17	06-Apr-17
04-Apr-17	DGT SW1 549	4000	<5	12	7.42	11-Apr-17	11-Apr-17
20-Apr-17	DGT SW1 550	3500	<5	1	7.75	01-May-17	01-May-17
09-May-17	DGT SW1 551	3500	<5	1	8.21	16-May-17	31-May-17
23-May-17	DGT SW1 552	4000	<5	2	7.48	08-Jun-17	15-Jun-17
07-Jun-17	DGT SW1 553	4000	<5	7	7.77	22-Jun-17	23-Jun-17
15-Jun-17	DGT SW1 554	3500	<5	5	8.35	22-Jun-17	23-Jun-17
06-Jul-17	DGT SW1 555	4000	<5	2	8.49	14-Jul-17	18-Jul-17
20-Jul-17	DGT SW1 556	3500	<5	4	8.17	26-Jul-17	27-Jul-17
02-Aug-17	DGT SW1 557	3500	<5	1.5	8.09	09-Aug-17	10-Aug-17
16-Aug-17	DGT SW1 558	4000	<5	2	8.29	21-Aug-17	21-Aug-17
31-Aug-17	DGT SW1 559	3500	<5	1	8.27	06-Sep-17	06-Sep-17
20-Sep-17	DGT SW1 560	4000	<5	2	8.47	27-Sep-17	03-Oct-17

06-Oct-17	DGT SW1 561	3500	<5	5.5	8.44	13-Sep-17	13-Oct-17
20-Oct-17	DGT SW1 562	4000	<5	2.5	7.70	27-Oct-17	30-Oct-17
02-Nov-17	DGT SW1 563	2500	<5	1	8.11	08-Nov-17	08-Nov-17
16-Nov-17	DGT SW1 564	2700	<5	1	8.16	23-Nov-17	28-Nov-17
1-Dec-17	DGT SW1 565	2500	<5	1	8.26	11-Dec-17	11-Dec-17
12-Dec-17	DGT SW1 566	2700	<5	1	8.23	21-Dec-17	21-Dec-17
22-Dec-17	DGT SW1 567	2500	<5	1	7.76	09-Jan-18	09-Jan-18
5-Jan-18	DGT SW1 568	2700	<5	1	7.95	15-Jan-18	15-Jan-18
16-Jan-18	DGT SW1 569	2500	<5	2.5	8.16	24-Jan-18	24-Jan-18
31-Jan-18	DGT SW1 570	2500	<5	1	7.89	07-Feb-18	7-Feb-18
13-Feb-18	DGT SW1 571	2500	<5	1	8.16	22-Feb-18	22-Feb-18
26-Feb-18	DGT SW1 572	2700	<5	6.5	7.56	06-Mar-18	06-Mar-18
7-Mar-18	DGT SW1 573	2700	<5	2.5	8.13	19-Mar-18	19-Mar-18
12-Mar-18	DGT SW1 574	2700	<5	1	8.29	19-Mar-18	19-Mar-18
21-Mar-18	DGT SW1 575	2700	<5	4	7.33	03-Apr-18	09-Apr-18
28-Mar-18	DGT SW1 576	2700	<5	2	7.9	11-Apr-18	11-Apr-18
6-Apr-18	DGT SW1 577	2700	<5	2	8.39	17-Apr-18	24-Apr-18
16-Apr-18	DGT SW1 578	2700	<5	1.5	8.18	24-Apr-18	24-Apr-18
24-Apr-18	DGT SW1 579	2700	<5	1.2	8.46	03-May-18	03-May-18
30-Apr-18	DGT SW1 580	2700	<5	4	8.03	08-May-18	16-May-18
8-May-18	DGT SW1 581	2700	<5	1.5	8.27	16-May-18	16-May-18
21-May-18	DGT SW1 582	2700	<5	1	8.02	01-Jun-18	04-Jun-18
30-May-18	DGT SW1 583	2700	<5	3	8.43	08-Jun-18	13-Jun-18
6-Jun-18	DGT SW1 584	4000	<5	5	8.02	14-Jun-18	14-Jun-18
11-Jun-18	DGT SW1 585	4000	<5	0.56	8.35	19-Jun-18	19-Jun-18
20-Jun-18	DGT SW1 586	4000	<5	7.8	8.00	29-Jun-18	02-Jul-18
26-Jun-18	DGT SW1 587	3000	<5	2	8.34	03-Jul-18	05-Jul-18
9-Jul-18	DGT SW1 588	2700	<5	1	8.48	18-Jul-18	18-Jul-18
27-Jul-18	DGT SW1 589	3000	<5	2	7.66	03-Aug-18	06-Aug-18
7-Aug-18	DGT SW1 590	2700	<5	1	7.96	14-Aug-18	14-Aug-18
17-Aug-18	DGT SW1 591	4000	<5	5	8	24-Aug-18	24-Aug-18
20-Aug-18	DGT SW1 592	3000	<5	1	8.18	31-Aug-18	03-Sep-18
29-Aug-18	DGT SW1 593	3000	<5	1	7.66	05-Sep-18	06-Sep-18

6-Sep-18	DGT SW1 594	2700	<5	2	8.06	20-Sep-18	21-Sep-18
18-Sep-18	DGT SW1 595	4000	<5	1	7.97	26-Sep-18	05-Oct-18
28-Sep-18	DGT SW1 596	3000	<5	4	7.94	09-Oct-18	12-Oct-18
5-Oct-18	DGT SW1 597	3000	11	44	8.37	12-Oct-18	15-Oct-18
12-Oct-18	DGT SW1 598	3000	<5	3.5	7.56	18-Oct-18	22-Oct-18
15-Oct-18	DGT SW1 599	3000	<5	13	7.85	22-Oct-18	24-Oct-18
18-Oct-18	DGT SW1 600	3000	<5	5.5	8.38	26-Oct-18	29-Oct-18
22-Oct-18	DGT SW1 601	4000	<5	1	8.28	30-Oct-18	07-Nov-18
25-Oct-18	DGT SW1 602	1000	<5	1	8.25	02-Nov-18	07-Nov-18
26-Oct-18	DGT SW1 603	100	<5	5.5	8.43	02-Nov-18	07-Nov-18
29-Oct-18	DGT SW1 604	100	<5	2	8.47	06-Nov-18	13-Nov-18
30-Oct-18	DGT SW1 605	20	<5	7	7.36	06-Nov-18	13-Nov-18
31-Oct-18	DGT SW1 606	20	<5	2	8.42	09-Nov-18	13-Nov-18
1-Nov-18	DGT SW1 607	20	<5	2	8.47	09-Nov-18	13-Nov-18
12-Nov-18	DGT SW1 608	2700	<5	8	7.77	21-Nov-18	28-Nov-18
27-Nov-18	DGT SW1 609	2000	<5	2	8.33	06-Dec-18	13-Dec-18
30-Nov-18	DGT SW1 610	2700	<5	5	8.11	07-Dec-18	13-Dec-18
14-Dec-18	DGT SW1 611	3000	<5	20	6.83	28-Dec-19	05-Jan-19
18-Dec-18	DGT SW1 612	2000	<5	8	8.34	28-Dec-19	05-Jan-19
24-Dec-18	DGT SW1 613	2700	<5	5	8.4	04-Jan-19	05-Jan-19
3-Jan-19	DGT SW1 614	2000	<5	1	8.12	11-Jan-19	23-Jan-19
11-Jan-19	DGT SW1 615	2700	<5	2	7.14	22-Jan-19	23-Jan-19
21-Jan-19	DGT SW1 616	2700	<5	16	8.43	30-Jan-19	04-Feb-19
30-Jan-19	DGT SW1 617	2700	<5	2.5	8.15	07-Feb-19	15-Feb-19
8-Feb-19	DGT SW1 618	2500	<5	2	8.47	14-Feb-19	25-Feb-19
13-Feb-19	DGT SW1 619	2700	<5	4	8.41	19-Feb-19	25-Feb-19
22-Feb-19	DGT SW1 620	2700	<5	1	8.02	01-Mar-19	08-Mar-19
5-Mar-19	DGT SW1 621	2700	<5	1	8.32	12-Mar-19	25-Mar-19
15-Mar-19	DGT SW1 622	3000	<5	23	8.28	21-Mar-19	25-Mar-19
18-Mar-19	DGT SW1 623	4000	<5	19	8.01	26-Mar-19	29-Mar-19

Heavy rainfall overnight and storm water run-off. No visible Oil&Grease during discharge.

25-Mar-19	DGT SW1 624	2700	<5	14	7.86	30-Mar-19	16-Apr-19
2-Apr-19	DGT SW1 625	2700	<5	2	7.92	08-Apr-19	16-Apr-19
10-Apr-19	DGT SW1 626	2000	<5	4	8.46	16-Apr-19	30-Apr-19
23-Apr-19	DGT SW1 627	2500	<5	1	7.91	30-Apr-19	03-Apr-19

EPA License Number: 4458

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 2 Monthly Summary

Note: does not include any monitoring conducted prior to 31 March 2012.

Special Frequency 1 means <10 days prior to discharge; and

Special Frequency 2 means <5 days prior to discharge

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Apr-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<4	<4	<4	20
	Manganese	milligrams per litre	Special Frequency 2	1	0.063	0.063	0.063	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2	1	5	5	5	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2	1	<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2	1	5	5	5	50
	Zinc	milligrams per litre	Special Frequency 2	1	0.0036	0.0036	0.0036	N/A
	pH	pH	Special Frequency 2	1	7.57	7.57	7.57	6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A

Jul-12	Nitrogen (total)	milligrams per litre	Special Frequency 2	No Discharges				N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Aug-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Sep-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Oct-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Nov-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Dec-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jan-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Feb-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Mar-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Apr-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10

	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jul-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Aug-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20

Sep-13	Manganese	milligrams per litre	Special Frequency 2	No Discharges				N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Oct-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Nov-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Dec-13	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jan-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A

	pH	pH	Special Frequency 2					6.5-8.5
Feb-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Mar-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Apr-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A

Jun-14	Oil and Grease	milligrams per litre	Special Frequency 2	No Discharges				10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jul-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Aug-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Sep-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Oct-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Nov-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Dec-14	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jan-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Feb-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Mar-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50

	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Apr-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	3	3	3	20
	Manganese	milligrams per litre	Special Frequency 2		0.108	0.108	0.108	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		5.4	5.4	5.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		16	16	16	50
	Zinc	milligrams per litre	Special Frequency 2		0.006	0.006	0.006	N/A
	pH	pH	Special Frequency 2		7.39	7.39	7.39	6.5-8.5
May-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jul-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A

Aug-15	Nitrogen (total)	milligrams per litre	Special Frequency 2	No Discharges				N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Sep-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Oct-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Nov-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Dec-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Jan-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	Manganese	milligrams per litre	Special Frequency 2		1.18	1.18	1.18	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		7.4	7.4	7.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		10	10	10	50
	Zinc	milligrams per litre	Special Frequency 2		0.018	0.018	0.018	N/A
	pH	pH	Special Frequency 2		7.47	7.47	7.47	6.5-8.5
Feb-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Mar-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Apr-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10

	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4	4	4	20
	Manganese	milligrams per litre	Special Frequency 2		0.134	0.134	0.134	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		9.2	9.2	9.2	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		17	17	17	50
	Zinc	milligrams per litre	Special Frequency 2		0.009	0.009	0.009	N/A
	pH	pH	Special Frequency 2		7.48	7.48	7.48	6.5-8.5
Jul-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Aug-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Sep-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20

Oct-16	Manganese	milligrams per litre	Special Frequency 2	No Discharges				N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Nov-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Dec-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jan-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Feb-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A

	pH	pH	Special Frequency 2					6.5-8.5
Mar-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	Manganese	milligrams per litre	Special Frequency 2		1.59	1.59	1.59	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		9.8	9.8	9.8	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		28	28	28	50
	Zinc	milligrams per litre	Special Frequency 2		0.017	0.017	0.017	N/A
	pH	pH	Special Frequency 2		7.7	7.7	7.7	6.5-8.5
Apr-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A

Jul-17	Oil and Grease	milligrams per litre	Special Frequency 2	No Discharges				10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Aug-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Sep-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Oct-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Nov-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Dec-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Jan-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Feb-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Mar-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Apr-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50

	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

May-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Jun-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Jul-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Aug-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A

Sep-18	Nitrogen (total)	milligrams per litre	Special Frequency 2	No Discharges				N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Oct-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Nov-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Dec-18	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Jan-19	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Feb-19	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Mar-19	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

Apr-19	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5

EPA License Number: 4458

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 2 Obtained Data

Note: does not include any monitoring conducted prior to 31 March 2012.

Date Sampled	DGT Sample No.	Biochemical Oxygen Demand (mg/L)	Manganese (mg/L)	Nitrogen Total (mg/L)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	Zinc (mg/L)	pH (pH)	Date Obatined	Date Published
12-Jun-12	DGT SW2027	<4	0.063	5	<5	5	0.0036	7.57	20-Jun-12	5-Jul-12
29-Apr-15	DGT SW2 028	3	0.108	5.4	<5	16	0.006	7.39	8-May-15	8-May-15
07-Jan-16	DGT SW2 029	<2	1.18	7.4	<5	10	0.018	7.47	15-Jan-16	18-Jan-16
08-Jun-16	DGT SW2 030	4	0.134	9.2	<5	17	0.009	7.48	16-Jun-16	17-Jun-16
01-Mar-17	DGT SW2 031	<2	1.59	9.8	<5	28	0.017	7.7	9-Mar-17	9-Mar-17