

EPA License Number: 4458 (Updated)

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 1 Monthly Summary

*Note: does not include any monitoring conducted prior to 31 March 2012.*

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Apr-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2.59	4.76	9.46	50
	pH	pH	Daily during any discharge	4	7.88	8.20	8.5	6.5-8.5
May-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2.73	3.95	5.16	50
	pH	pH	Daily during any discharge	2	7.94	8.09	8.24	6.5-8.5
Jun-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	7.25	20	50
	pH	pH	Daily during any discharge	4	7.39	7.74	7.96	6.5-8.5
Jul-12	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	4	4	4	50
	pH	pH	Daily during any discharge	1	7.27	7.27	7.27	6.5-8.5
Aug-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	2	2	50
	pH	pH	Daily during any discharge	2	7.45	7.71	7.97	6.5-8.5
Sep-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4	7	50
	pH	pH	Daily during any discharge	2	7.55	7.66	7.77	6.5-8.5

<b>Oct-12</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	2	19.25	37	50
	<b>pH</b>	pH	Daily during any discharge	4	6.67	7.24	7.66	6.5-8.5
<b>Nov-12</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	3	4.3	6	50
	<b>pH</b>	pH	Daily during any discharge	3	7.69	7.76	7.79	6.5-8.5
<b>Dec-12</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	2.3	5	50
	<b>pH</b>	pH	Daily during any discharge	3	7.25	8.0	8.48	6.5-8.5
<b>Jan-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	<b>pH</b>	pH	Daily during any discharge	2	8.17	8.3	8.35	6.5-8.5
<b>Feb-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	<b>pH</b>	pH	Daily during any discharge	2	8.45	8.48	8.5	6.5-8.5
<b>Mar-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	9.0	22	50
	<b>pH</b>	pH	Daily during any discharge	3	8.28	8.36	8.45	6.5-8.5
<b>Apr-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	3	6.0	10	50
	<b>pH</b>	pH	Daily during any discharge	3	7.56	8.01	8.36	6.5-8.5
<b>May-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	3	5.0	8	50
	<b>pH</b>	pH	Daily during any discharge	3	7.64	7.78	7.96	6.5-8.5
<b>Jun-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	5	1	5.3	10	50
	<b>pH</b>	pH	Daily during any discharge	5	7.67	7.99	8.42	6.5-8.5

<b>Jul-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	<b>pH</b>	pH	Daily during any discharge	2	8.17	8.30	8.43	6.5-8.5
<b>Aug-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	4	5.0	6	50
	<b>pH</b>	pH	Daily during any discharge	2	7.64	7.83	8.02	6.5-8.5
<b>Sep-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	0.5	2.2	5	50
	<b>pH</b>	pH	Daily during any discharge	3	7.81	8.08	8.45	6.5-8.5
<b>Oct-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	5	5.5	6	50
	<b>pH</b>	pH	Daily during any discharge	2	7.61	7.69	7.76	6.5-8.5
<b>Nov-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	7	25.0	38	50
	<b>pH</b>	pH	Daily during any discharge	3	7.68	8.19	8.47	6.5-8.5
<b>Dec-13</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	2	5.0	10	50
	<b>pH</b>	pH	Daily during any discharge	3	6.81	7.60	8.35	6.5-8.5
<b>Jan-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	2.0	3	50
	<b>pH</b>	pH	Daily during any discharge	3	7.96	8.16	8.32	6.5-8.5
<b>Feb-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	5	1	3.2	7	50
	<b>pH</b>	pH	Daily during any discharge	5	6.71	7.53	8.48	6.5-8.5
<b>Mar-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	5	1	3.0	6	50
	<b>pH</b>	pH	Daily during any discharge	5	6.64	7.29	7.93	6.5-8.5

<b>Apr-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	6	1	3.7	11	50
	<b>pH</b>	pH	Daily during any discharge	6	6.95	7.48	8.19	6.5-8.5
<b>May-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	6	0.5	1.8	6	50
	<b>pH</b>	pH	Daily during any discharge	6	6.57	7.34	7.67	6.5-8.5
<b>Jun-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	6	0.5	1.3	3	50
	<b>pH</b>	pH	Daily during any discharge	6	7.18	7.57	7.91	6.5-8.5
<b>Jul-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	3	7.58	8.00	8.37	6.5-8.5
<b>Aug-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	1	8.5	23	50
	<b>pH</b>	pH	Daily during any discharge	4	6.62	7.97	8.47	6.5-8.5
<b>Sep-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	1	5	5.0	5	50
	<b>pH</b>	pH	Daily during any discharge	1	7.92	7.92	7.92	6.5-8.5
<b>Oct-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	1	28	28.0	28	50
	<b>pH</b>	pH	Daily during any discharge	1	6.99	6.99	6.99	6.5-8.5
<b>Nov-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	<b>pH</b>	pH	Daily during any discharge	2	6.69	7.41	8.12	6.5-8.5
<b>Dec-14</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	2	18.7	28	50
	<b>pH</b>	pH	Daily during any discharge	3	6.56	7.42	8.23	6.5-8.5

Jan-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	0.5	4.5	10	50
	pH	pH	Daily during any discharge	3	7.37	7.83	8.09	6.5-8.5
Feb-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.1	8.10	8.1	6.5-8.5
Mar-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	8.25	8.31	8.37	6.5-8.5
Apr-15	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	3	12.8	23	50
	pH	pH	Daily during any discharge	5	8.03	8.33	8.43	6.5-8.5
May-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	6.66	7.29	7.92	6.5-8.5
Jun-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	6	8	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	5.7	11	50
	pH	pH	Daily during any discharge	3	7.52	8.03	8.34	6.5-8.5
Jul-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	7.96	7.96	7.96	6.5-8.5
Aug-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	10.0	19	50
	pH	pH	Daily during any discharge	2	7.37	7.76	8.14	6.5-8.5
Sep-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.05	8.26	8.47	6.5-8.5

<b>Oct-15</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	8.5	12	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	3	5.7	8	50
	<b>pH</b>	pH	Daily during any discharge	3	7.22	7.68	7.97	6.5-8.5
<b>Nov-15</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	1	8.0	26	50
	<b>pH</b>	pH	Daily during any discharge	4	8.42	8.44	8.46	6.5-8.5
<b>Dec-15</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	3.3	5.5	50
	<b>pH</b>	pH	Daily during any discharge	2	7.01	7.69	8.37	6.5-8.5
<b>Jan-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	1	4.8	10	50
	<b>pH</b>	pH	Daily during any discharge	4	7.90	8.04	8.25	6.5-8.5
<b>Feb-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	38.5	72	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	3	5.5	8	50
	<b>pH</b>	pH	Daily during any discharge	2	7.91	8.04	8.16	6.5-8.5
<b>Mar-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	1	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	1	8.04	8.04	8.04	6.5-8.5
<b>Apr-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	2	8.01	8.07	8.12	6.5-8.5
<b>May-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	2	7.23	7.56	7.89	6.5-8.5
<b>Jun-16</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	8.4	27	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	1	15.3	27	50
	<b>pH</b>	pH	Daily during any discharge	4	7.09	7.68	8.17	6.5-8.5

Jul-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	4.5	7	50
	pH	pH	Daily during any discharge	2	7.90	8.04	8.17	6.5-8.5
Aug-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.35	8.35	6.5-8.5
Sep-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	8.23	8.23	8.23	6.5-8.5
Oct-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.37	8.37	8.37	6.5-8.5
Nov-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4.5	8	50
	pH	pH	Daily during any discharge	2	8.25	8.27	8.29	6.5-8.5
Dec-16	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	4.0	6	50
	pH	pH	Daily during any discharge	3	7.46	7.95	8.22	6.5-8.5
Jan-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.36	8.36	6.5-8.5
Feb-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	9.0	17	50
	pH	pH	Daily during any discharge	2	7.76	8.06	8.35	6.5-8.5
Mar-17	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	20.8	38	50
	pH	pH	Daily during any discharge	4	7.78	8.01	8.29	6.5-8.5

<b>Apr-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	6.5	12	50
	<b>pH</b>	pH	Daily during any discharge	2	7.42	7.59	7.75	6.5-8.5
<b>May-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	<b>pH</b>	pH	Daily during any discharge	2	7.48	7.85	8.21	6.5-8.5
<b>Jun-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	5	6.0	7	50
	<b>pH</b>	pH	Daily during any discharge	2	7.77	8.06	8.35	6.5-8.5
<b>Jul-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	2	3.0	4	50
	<b>pH</b>	pH	Daily during any discharge	2	8.17	8.33	8.49	6.5-8.5
<b>Aug-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	1.5	2	50
	<b>pH</b>	pH	Daily during any discharge	3	8.09	8.22	8.29	6.5-8.5
<b>Sep-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	<b>pH</b>	pH	Daily during any discharge	1	8.47	8.47	8.47	6.5-8.5
<b>Oct-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	2.5	4.0	5.5	50
	<b>pH</b>	pH	Daily during any discharge	2	7.70	8.07	8.44	6.5-8.5
<b>Nov-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	2	8.11	8.14	8.16	6.5-8.5
<b>Dec-17</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	1	1.0	1	50
	<b>pH</b>	pH	Daily during any discharge	3	7.76	8.08	8.26	6.5-8.5



Jan-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.5	2.5	50
	pH	pH	Daily during any discharge	3	7.89	8.00	8.16	6.5-8.5
Feb-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.8	6.5	50
	pH	pH	Daily during any discharge	2	7.56	7.86	8.16	6.5-8.5
Mar-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.4	4	50
	pH	pH	Daily during any discharge	4	7.33	7.91	8.29	6.5-8.5
Apr-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1.2	2.2	4	50
	pH	pH	Daily during any discharge	4	8.03	8.27	8.46	6.5-8.5
May-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.8	3	50
	pH	pH	Daily during any discharge	3	8.02	8.24	8.43	6.5-8.5
Jun-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	0.56	3.8	7.8	50
	pH	pH	Daily during any discharge	4	8.00	8.18	8.35	6.5-8.5
Jul-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	7.66	8.07	8.48	6.5-8.5
Aug-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.0	5	50
	pH	pH	Daily during any discharge	4	7.66	7.95	8.18	6.5-8.5
Sep-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	7.94	7.99	8.06	6.5-8.5

<b>Oct-18</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	10	<5	5.60	11	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	10	1	8.5	44	50
	<b>pH</b>	pH	Daily during any discharge	10	7.36	8.14	8.47	6.5-8.5

<b>Nov-18</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	2	4.3	8	50
	<b>pH</b>	pH	Daily during any discharge	4	7.77	8.17	8.47	6.5-8.5

<b>Dec-18</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	3	5	11.0	20	50
	<b>pH</b>	pH	Daily during any discharge	3	6.83	7.86	8.40	6.5-8.5

<b>Jan-19</b>	<b>Oil and Grease</b>	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	<b>Total suspended solids</b>	milligrams per litre	Daily during any discharge	4	1	5.4	16	50
	<b>pH</b>	pH	Daily during any discharge	4	7.14	7.96	8.43	6.5-8.5

EPA License Number: 4458

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW1 2164

POINT 1 Obtained Data

*Note: does not include any monitoring conducted prior to 31 March 2012.*

Date Sampled	DGT Sample No.	Volume Discharged (kL)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	pH (pH)	Date Obatined	Date Published
03-Apr-12	DGT SW1 382	4000	<5	4	8.5	26-Apr-12	5-Jul-12
17-Apr-12	DGT SW1 383	4000	<5	2.59	8.26	26-Apr-12	5-Jul-12
18-Apr-12	DGT SW1 384	4500	<5	9.46	7.88	31-May-12	5-Jul-12
26-Apr-12	DGT SW1 385	4000	<5	3	8.17	31-May-12	5-Jul-12
11-May-12	DGT SW1 386	4000	<5	5.16	7.94	31-May-12	5-Jul-12
23-May-12	DGT SW1 387	4000	<5	2.73	8.24	31-May-12	5-Jul-12
01-Jun-12	DGT SW1 388	3500	<5	1	7.96	13-Jun-12	5-Jul-12
06-Jun-12	DGT SW1 389	3000	<5	7	7.39	13-Jun-12	5-Jul-12
12-Jun-12	DGT SW1 390	4500	<5	20	7.69	20-Jun-12	5-Jul-12
28-Jun-12	DGT SW1 391	3500	<5	1	7.93	5-Jul-12	5-Jul-12
11-Jul-12	DGT SW1 392	3000	<5	4	7.27	2-Aug-12	2-Aug-12
10-Aug-12	DGT SW1 393	4000	<5	2	7.97	16-Aug-12	16-Aug-12
27-Aug-12	DGT SW1 394	4000	<5	2	7.45	3-Sep-12	3-Sep-12
11-Sep-12	DGT SW1 395	4000	<5	7	7.55	25-Sep-12	25-Sep-12
25-Sep-12	DGT SW1 396	3500	<5	1	7.77	3-Oct-12	8-Oct-12
10-Oct-12	DGT SW1 397	3500	<5	2	7.66	17-Oct-12	22-Oct-12
15-Oct-12	DGT SW1 398	3500	<5	19	7.31	22-Oct-12	22-Oct-12
22-Oct-12	DGT SW1 399	2000	<5	19	7.31	30-Oct-12	30-Oct-12
26-Oct-10	DGT SW1 400	2000	<5	37	6.67	31-Oct-12	31-Oct-12
07-Nov-12	DGT SW1 401	4000	<5	4	7.79	13-Nov-12	13-Nov-12
15-Nov-12	DGT SW1 402	2500	<5	6	7.69	23-Nov-12	23-Nov-12
26-Nov-12	DGT SW1 403	3500	<5	3	7.79	4-Dec-12	4-Dec-12

06-Dec-12	DGT SW1 404	3000	<5	1	7.25	13-Dec-12	13-Dec-12
17-Dec-12	DGT SW1 405	3500	<5	1	8.48	21-Dec-12	21-Dec-12
27-Dec-12	DGT SW1 406	4000	<5	5	8.41	9-Jan-13	9-Jan-13
10-Jan-13	DGT SW1 407	4000	<5	1	8.17	17-Jan-13	17-Jan-13
22-Jan-13	DGT SW1 408	3000	<5	2	8.35	30-Jan-13	30-Jan-13
04-Feb-13	DGT SW1 409	4000	<5	5	8.5	12-Feb-13	13-Feb-13
12-Feb-13	DGT SW1 410	3000	<5	3	8.45	19-Feb-13	19-Feb-13
01-Mar-13	DGT SW1 411	4000	<5	22	8.45	11-Mar-13	11-Mar-13
07-Mar-13	DGT SW1 412	2500	<5	4	8.28	13-Mar-13	13-Mar-13
22-Mar-13	DGT SW1 413	3000	<5	1	8.35	4-Apr-13	4-Apr-13
08-Apr-13	DGT SW1 414	4000	<5	5	8.11	15-Apr-13	15-Apr-13
19-Apr-13	DGT SW1 415	3500	<5	3	8.36	29-Apr-13	29-Apr-13
24-Apr-13	DGT SW1 416	3200	<5	10	7.56	2-May-13	3-May-13
07-May-13	DGT SW1 417	3000	<5	3	7.73	15-May-13	16-May-13
21-May-13	DGT SW1 418	3500	<5	4	7.96	30-May-13	3-Jun-13
27-May-13	DGT SW1 419	4000	<5	8	7.64	3-Jun-13	3-Jun-13
05-Jun-13	DGT SW1 420	3500	<5	8.5	7.67	14-Jun-13	14-Jun-13
17-Jun-13	DGT SW1 421	3500	<5	2	8.05	25-Jun-13	26-Jun-13
19-Jun-13	DGT SW1 422	1500	<5	1	7.90	27-Jun-13	27-Jun-13
24-Jun-13	DGT SW1 423	3000	<5	10	8.42	1-Jul-13	2-Jul-13
26-Jun-13	DGT SW1 424	3500	<5	5	7.89	3-Jul-13	4-Jul-13
08-Jul-13	DGT SW1 425	3000	<5	3	8.43	16-Jul-13	16-Jul-13
24-Jul-13	DGT SW1 426	3000	<5	1	8.17	1-Aug-13	2-Aug-13
08-Aug-13	DGT SW1 427	3000	<5	6	8.02	15-Aug-13	15-Aug-13
26-Aug-13	DGT SW1 428	3500	<5	4	7.64	5-Sep-13	5-Sep-13
09-Sep-13	DGT SW1 429	3500	<5	1	7.97	17-Sep-13	18-Sep-13
18-Sep-13	DGT SW1 430	4000	<5	5	8.45	26-Sep-13	27-Sep-13
28-Sep-13	DGT SW1 431	3500	<5	0.5	7.81	8-Oct-13	8-Oct-13
10-Oct-13	DGT SW1 432	3000	<5	6	7.61	21-Oct-13	21-Oct-13
24-Oct-13	DGT SW1 433	3500	<5	5	7.76	1-Nov-13	1-Nov-13
11-Nov-13	DGT SW1 434	3500	<5	30	8.47	19-Nov-11	20-Nov-13
19-Nov-13	DGT SW1 435	4000	<5	38	8.43	26-Nov-13	27-Nov-13
27-Nov-13	DGT SW1 436	2500	<5	7	7.68	4-Dec-13	4-Dec-13

06-Dec-13	DGT SW1 437	3000	<5	10	7.63	16-Dec-13	17-Dec-13
17-Dec-13	DGT SW1 438	2500	<5	2	8.35	9-Jan-13	9-Jan-13
28-Dec-13	DGT SW1 439	3500	<5	3	6.81	16-Jan-14	20-Jan-14
08-Jan-13	DGT SW1 440	3500	<5	3	8.32	16-Jan-14	20-Jan-14
21-Jan-14	DGT SW1 441	4000	<5	2	7.96	29-Jan-14	29-Jan-14
29-Jan-14	DGT SW1 442	4000	<5	1	8.21	5-Feb-14	6-Feb-14
06-Feb-14	DGT SW1 443	4000	<5	1	6.95	14-Feb-14	26-Feb-14
13-Feb-14	DGT SW1 444	3000	<5	1	8.48	25-Feb-14	26-Feb-14
18-Feb-14	DGT SW1 445	3500	<5	7	6.71	25-Feb-14	26-Feb-14
24-Feb-14	DGT SW1 446	4000	<5	4	7.67	3-Mar-14	3-Mar-14
28-Feb-14	DGT SW1 447	2500	<5	3	7.85	7-Mar-14	10-Mar-14
03-Mar-14	DGT SW1 448	4000	<5	6	7.93	11-Mar-14	11-Mar-14
10-Mar-14	DGT SW1 449	4500	<5	2	7.57	18-Mar-14	19-Mar-14
17-Mar-14	DGT SW1 450	4000	<5	1	7.41	1-Apr-14	15-Apr-14
24-Mar-14	DGT SW1 451	4000	<5	1	6.91	1-Apr-14	15-Apr-14
31-Mar-14	DGT SW1 452	4000	<5	5	6.64	10-Apr-14	15-Apr-14
03-Apr-14	DGT SW1 453	2000	<5	2.5	7.42	10-Apr-14	15-Apr-14
08-Apr-14	DGT SW1 454	4000	<5	1.6	6.95	16-Apr-14	16-Apr-14
11-Apr-14	DGT SW1 455	4000	<5	11	7.7	28-Apr-14	28-Apr-14
15-Apr-14	DGT SW1 456	3500	<5	5	7.06	28-Apr-14	28-Apr-14
22-Apr-14	DGT SW1 457	4500	<5	1	7.54	29-Apr-14	30-Apr-14
27-Apr-14	DGT SW1 458	4500	<5	1	8.19	6-May-14	7-May-14
02-May-14	DGT SW1 459	4500	<5	1	7.09	9-May-14	12-May-14
07-May-14	DGT SW1 460	4500	<5	1	6.57	21-May-14	26-May-14
12-May-14	DGT SW1 461	4500	<5	0.5	7.47	21-May-14	26-May-14
16-May-14	DGT SW1 462	4500	<5	1	7.57	3-Jun-14	5-Jun-14
21-May-14	DGT SW1 463	3000	<5	6	7.67	3-Jun-14	5-Jun-14
27-May-14	DGT SW1 464	2000	<5	1	7.65	3-Jun-14	5-Jun-14
02-Jun-14	DGT SW1 465	200	<5	2	7.42	20-Jun-14	20-Jun-14
03-Jun-14	DGT SW1 466	4000	<5	1	7.41	20-Jun-14	20-Jun-14
11-Jun-14	DGT SW1 467	2000	<5	3	7.69	20-Jun-14	20-Jun-14
20-Jun-14	DGT SW1 468	4000	<5	0.5	7.18	1-Jul-14	1-Jul-14
25-Jun-14	DGT SW1 469	4000	<5	0.5	7.91	3-Jul-14	7-Jul-14

30-Jun-14	DGT SW1 470	4000	<5	0.5	7.8	8-Jul-14	9-Jul-14
10-Jul-14	DGT SW1 471	3500	<5	1	8.06	23-Jul-14	24-Jul-14
18-Jul-14	DGT SW1 472	3000	<5	1	7.58	28-Jul-14	28-Jul-14
29-Jul-14	DGT SW1 473	3500	<5	1	8.37	4-Aug-14	5-Aug-14
06-Aug-14	DGT SW1 474	3500	<5	1	8.44	20-Aug-14	21-Aug-14
13-Aug-14	DGT SW1 475	4000	<5	2	8.35	20-Aug-14	21-Aug-14
18-Aug-14	DGT SW1 476	4000	<5	23	8.47	26-Aug-14	27-Aug-14
28-Aug-14	DGT SW1 477	3500	<5	8	6.62	4-Sep-14	5-Sep-14
24-Sep-14	DGT SW1 478	3000	<5	5	7.92	3-Oct-14	7-Oct-14
15-Oct-14	DGT SW1 479	4000	<5	28	6.99	29-Oct-14	30-Oct-14
11-Nov-14	DGT SW1 480	3500	<5	5	6.69	19-Nov-14	21-Nov-14
26-Nov-14	DGT SW1 481	4000	<5	3	8.12	4-Dec-14	4-Dec-14
04-Dec-14	DGT SW1 482	4000	<5	28	6.56	11-Dec-14	12-Dec-14
08-Dec-14	DGT SW1 483	4000	<5	26	7.46	16-Dec-14	16-Dec-14
18-Dec-14	DGT SW1 484	2000	<5	2	8.23	5-Jan-15	5-Jan-15
08-Jan-15	DGT SW1 485	2000	<5	0.5	8.04	19-Jan-15	20-Jan-15
12-Jan-15	DGT SW1 486	4000	<5	10	7.37	4-Feb-15	5-Feb-15
27-Jan-15	DGT SW1 487	2000	<5	3	8.09	4-Feb-15	5-Feb-15
09-Feb-15	DGT SW1 488	4000	<5	2	8.1	17-Feb-15	24-Feb-15
04-Mar-15	DGT SW1 489	4000	<5	3	8.25	11-Mar-15	12-Mar-15
20-Mar-15	DGT SW1 490	1500	<5	4	8.37	26-Mar-15	27-Mar-15
01-Apr-15	DGT SW1 491	4000	<5	4	8.42	10-Apr-15	16-Apr-15
17-Apr-15	DGT SW1 492	4000	<5	3	8.38	24-Apr-15	24-Apr-15
21-Apr-15	DGT SW1 493	4000	<5	21	8.43	1-May-15	1-May-15
22-Apr-15	DGT SW1 494	4000	<5	23	8.03	1-May-15	1-May-15
29-Apr-15	DGT SW1 495	4000	<5	13	8.39	6-May-15	7-May-15
11-May-15	DGT SW1 496	4000	<5	3	6.66	18-May-15	18-May-15
29-May-15	DGT SW1 497	3500	<5	4	7.92	4-Jun-15	5-Jun-15
17-Jun-15	DGT SW1 498	4000	<5	5	8.23	25-Jun-15	25-Jun-15
23-Jun-15	DGT SW1 499	3500	8	11	7.52	2-Jul-15	3-Jul-15
26-Jun-15	DGT SW1 500	3000	<5	1	8.34	2-Jul-15	3-Jul-15
20-Jul-15	DGT SW1 501	4000	<5	6	7.96	27-Jul-15	29-Jul-15
12-Aug-15	DGT SW1 502	4000	<5	1	8.14	20-Aug-15	21-Aug-15

25-Aug-15	DGT SW1 503	4000	<5	19	7.37	1-Sep-15	4-Sep-15
07-Sep-15	DGT SW1 504	4000	<5	3	8.47	15-Sep-15	16-Sep-15
21-Sep-15	DGT SW1 505	4000	<5	1	8.05	2-Oct-15	6-Oct-15
06-Oct-15	DGT SW1 506	4000	<5	6	7.84	14-Oct-15	14-Oct-15
19-Oct-15	DGT SW1 507	4000	<5	8	7.97	26-Oct-15	26-Oct-15
26-Oct-15	DGT SW1 508	3500	12	3	7.22	04-Nov-15	04-Nov-15
02-Nov-15	DGT SW1 509	4000	<5	2	8.45	13-Nov-15	17-Nov-15
13-Nov-15	DGT SW1 510	4000	10	26	8.42	23-Nov-15	24-Nov-15
20-Nov-15	DGT SW1 511	4000	<5	3	8.46	27-Nov-15	27-Nov-15
30-Nov-15	DGT SW1 512	4000	<5	1	8.42	18-Dec-15	31-Dec-15
10-Dec-15	DGT SW1 513	3500	<5	1	8.37	18-Dec-15	31-Dec-15
22-Dec-15	DGT SW1 514	4000	<5	5.5	7.01	14-Jan-16	15-Jan-16
04-Jan-16	DGT SW1 515	4000	<5	7	8.10	14-Jan-16	15-Jan-16
06-Jan-16	DGT SW1 516	3000	<5	10	8.25	14-Jan-16	15-Jan-16
18-Jan-16	DGT SW1 517	3500	<5	1	7.92	25-Jan-16	27-Jan-16
27-Jan-16	DGT SW1 518	3500	5	1	7.9	03-Feb-15	08-Feb-15
05-Feb-16	DGT SW1 519	3000	<5	8	7.91	12-Feb-16	15-Feb-16
22-Feb-16	DGT SW1 520	3000	72	3	8.16	08-Mar-16	10-Mar-16
13-Mar-16	DGT SW1 521	3500	<5	1	8.04	23-Mar-16	14-Apr-16
06-Apr-16	DGT SW1 522	3500	<5	1	8.12	12-Apr-16	14-Apr-16
21-Apr-16	DGT SW1 523	3500	<5	1	8.01	13-May-16	16-May-16
06-May-16	DGT SW1 524	3000	<5	1	7.23	13-May-16	16-May-16
24-May-16	DGT SW1 525	3500	<5	1	7.89	16-Jun-16	17-Jun-16
05-Jun-16	DGT SW1 526	4000	27	27	7.09	16-Jun-16	17-Jun-16
05-Jun-16	DGT SW1 527	2800	<5	27	7.56	16-Jun-16	17-Jun-16

Sample Potentially Contaminated.No visible Oil&Grease during discharge. Not consistant with past and present results

Thunderstorms in Sydney, emergency discharges to prevent flooding. Not representative Sample

17-Jun-16	DGT SW1 528	3500	<5	6	7.88	06-Jul-16	13-Jul-16
29-Jun-16	DGT SW1 529	4000	<5	1	8.17	06-Jul-16	13-Jul-16
15-Jul-16	DGT SW1 530	4000	<5	7	8.17	29-Jul-16	03-Aug-16
26-Jul-16	DGT SW1 531	4000	<5	2	7.9	29-Jul-16	03-Aug-16
12-Aug-16	DGT SW1 532	4000	<5	3	8.35	22-Aug-16	24-Aug-16
25-Aug-16	DGT SW1 533	4000	<5	1	8.35	01-Sep-16	09-Sep-16
14-Sep-16	DGT SW1 534	4000	<5	6	8.23	21-Sep-16	23-Sep-16
13-Oct-16	DGT SW1 535	4000	<5	2	8.37	21-Oct-16	31-Oct-16
02-Nov-16	DGT SW1 536	4000	<5	8	8.29	09-Nov-16	10-Nov-16
21-Nov-16	DGT SW1 537	3500	<5	1	8.25	28-Nov-16	29-Nov-16
05-Dec-16	DGT SW1 538	3500	<5	2	8.22	14-Dec-16	05-Jan-17
16-Dec-16	DGT SW1 539	4000	<5	6	8.17	16-Jan-17	17-Jan-17
29-Dec-16	DGT SW1 540	2400	<5	4	7.46	20-Jan-17	23-Jan-17
10-Jan-17	DGT SW1 541	2500	<5	1	8.36	20-Jan-17	20-Jan-17
30-Jan-17	DGT SW1 542	4000	<5	3	8.35	13-Feb-17	13-Feb-17
14-Feb-17	DGT SW1 543	4000	<5	1	8.35	24-Feb-17	24-Feb-17
27-Feb-17	DGT SW1 544	4000	<5	17	7.76	08-Mar-17	09-Mar-17
02-Mar-17	DGT SW1 545	3500	<5	38	8.29	08-Mar-17	09-Mar-17
14-Mar-17	DGT SW1 546	3500	<5	8	7.87	20-Mar-17	21-Mar-17
18-Mar-17	DGT SW1 547	3000	<5	36.3	8.11	27-Mar-17	27-Mar-17
29-Mar-17	DGT SW1 548	4000	<5	1	7.78	06-Apr-17	06-Apr-17
04-Apr-17	DGT SW1 549	4000	<5	12	7.42	11-Apr-17	11-Apr-17
20-Apr-17	DGT SW1 550	3500	<5	1	7.75	01-May-17	01-May-17
09-May-17	DGT SW1 551	3500	<5	1	8.21	16-May-17	31-May-17
23-May-17	DGT SW1 552	4000	<5	2	7.48	08-Jun-17	15-Jun-17
07-Jun-17	DGT SW1 553	4000	<5	7	7.77	22-Jun-17	23-Jun-17
15-Jun-17	DGT SW1 554	3500	<5	5	8.35	22-Jun-17	23-Jun-17
06-Jul-17	DGT SW1 555	4000	<5	2	8.49	14-Jul-17	18-Jul-17
20-Jul-17	DGT SW1 556	3500	<5	4	8.17	26-Jul-17	27-Jul-17
02-Aug-17	DGT SW1 557	3500	<5	1.5	8.09	09-Aug-17	10-Aug-17
16-Aug-17	DGT SW1 558	4000	<5	2	8.29	21-Aug-17	21-Aug-17
31-Aug-17	DGT SW1 559	3500	<5	1	8.27	06-Sep-17	06-Sep-17
20-Sep-17	DGT SW1 560	4000	<5	2	8.47	27-Sep-17	03-Oct-17



06-Oct-17	DGT SW1 561	3500	<5	5.5	8.44	13-Sep-17	13-Oct-17
20-Oct-17	DGT SW1 562	4000	<5	2.5	7.70	27-Oct-17	30-Oct-17
02-Nov-17	DGT SW1 563	2500	<5	1	8.11	08-Nov-17	08-Nov-17
16-Nov-17	DGT SW1 564	2700	<5	1	8.16	23-Nov-17	28-Nov-17
1-Dec-17	DGT SW1 565	2500	<5	1	8.26	11-Dec-17	11-Dec-17
12-Dec-17	DGT SW1 566	2700	<5	1	8.23	21-Dec-17	21-Dec-17
22-Dec-17	DGT SW1 567	2500	<5	1	7.76	09-Jan-18	09-Jan-18
5-Jan-18	DGT SW1 568	2700	<5	1	7.95	15-Jan-18	15-Jan-18
16-Jan-18	DGT SW1 569	2500	<5	2.5	8.16	24-Jan-18	24-Jan-18
31-Jan-18	DGT SW1 570	2500	<5	1	7.89	07-Feb-18	7-Feb-18
13-Feb-18	DGT SW1 571	2500	<5	1	8.16	22-Feb-18	22-Feb-18
26-Feb-18	DGT SW1 572	2700	<5	6.5	7.56	06-Mar-18	06-Mar-18
7-Mar-18	DGT SW1 573	2700	<5	2.5	8.13	19-Mar-18	19-Mar-18
12-Mar-18	DGT SW1 574	2700	<5	1	8.29	19-Mar-18	19-Mar-18
21-Mar-18	DGT SW1 575	2700	<5	4	7.33	03-Apr-18	09-Apr-18
28-Mar-18	DGT SW1 576	2700	<5	2	7.9	11-Apr-18	11-Apr-18
6-Apr-18	DGT SW1 577	2700	<5	2	8.39	17-Apr-18	24-Apr-18
16-Apr-18	DGT SW1 578	2700	<5	1.5	8.18	24-Apr-18	24-Apr-18
24-Apr-18	DGT SW1 579	2700	<5	1.2	8.46	03-May-18	03-May-18
30-Apr-18	DGT SW1 580	2700	<5	4	8.03	08-May-18	16-May-18
8-May-18	DGT SW1 581	2700	<5	1.5	8.27	16-May-18	16-May-18
21-May-18	DGT SW1 582	2700	<5	1	8.02	01-Jun-18	04-Jun-18
30-May-18	DGT SW1 583	2700	<5	3	8.43	08-Jun-18	13-Jun-18
6-Jun-18	DGT SW1 584	4000	<5	5	8.02	14-Jun-18	14-Jun-18
11-Jun-18	DGT SW1 585	4000	<5	0.56	8.35	19-Jun-18	19-Jun-18
20-Jun-18	DGT SW1 586	4000	<5	7.8	8.00	29-Jun-18	02-Jul-18
26-Jun-18	DGT SW1 587	3000	<5	2	8.34	03-Jul-18	05-Jul-18
9-Jul-18	DGT SW1 588	2700	<5	1	8.48	18-Jul-18	18-Jul-18
27-Jul-18	DGT SW1 589	3000	<5	2	7.66	03-Aug-18	06-Aug-18
7-Aug-18	DGT SW1 590	2700	<5	1	7.96	14-Aug-18	14-Aug-18
17-Aug-18	DGT SW1 591	4000	<5	5	8	24-Aug-18	24-Aug-18
20-Aug-18	DGT SW1 592	3000	<5	1	8.18	31-Aug-18	03-Sep-18
29-Aug-18	DGT SW1 593	3000	<5	1	7.66	05-Sep-18	06-Sep-18

6-Sep-18	DGT SW1 594	2700	<5	2	8.06	20-Sep-18	21-Sep-18
18-Sep-18	DGT SW1 595	4000	<5	1	7.97	26-Sep-18	05-Oct-18
28-Sep-18	DGT SW1 596	3000	<5	4	7.94	09-Oct-18	12-Oct-18
5-Oct-18	DGT SW1 597	3000	11	44	8.37	12-Oct-18	15-Oct-18
12-Oct-18	DGT SW1 598	3000	<5	3.5	7.56	18-Oct-18	22-Oct-18
15-Oct-18	DGT SW1 599	3000	<5	13	7.85	22-Oct-18	24-Oct-18
18-Oct-18	DGT SW1 600	3000	<5	5.5	8.38	26-Oct-18	29-Oct-18
22-Oct-18	DGT SW1 601	4000	<5	1	8.28	30-Oct-18	07-Nov-18
25-Oct-18	DGT SW1 602	1000	<5	1	8.25	02-Nov-18	07-Nov-18
26-Oct-18	DGT SW1 603	100	<5	5.5	8.43	02-Nov-18	07-Nov-18
29-Oct-18	DGT SW1 604	100	<5	2	8.47	06-Nov-18	13-Nov-18
30-Oct-18	DGT SW1 605	20	<5	7	7.36	06-Nov-18	13-Nov-18
31-Oct-18	DGT SW1 606	20	<5	2	8.42	09-Nov-18	13-Nov-18
1-Nov-18	DGT SW1 607	20	<5	2	8.47	09-Nov-18	13-Nov-18
12-Nov-18	DGT SW1 608	2700	<5	8	7.77	21-Nov-18	28-Nov-18
27-Nov-18	DGT SW1 609	2000	<5	2	8.33	06-Dec-18	13-Dec-18
30-Nov-18	DGT SW1 610	2700	<5	5	8.11	07-Dec-18	13-Dec-18
14-Dec-18	DGT SW1 611	3000	<5	20	6.83	28-Dec-19	05-Jan-19
18-Dec-18	DGT SW1 612	2000	<5	8	8.34	28-Dec-19	05-Jan-19
24-Dec-18	DGT SW1 613	2700	<5	5	8.4	04-Jan-19	05-Jan-19
3-Jan-19	DGT SW1 614	2000	<5	1	8.12	11-Jan-19	23-Jan-19
11-Jan-19	DGT SW1 615	2700	<5	2	7.14	22-Jan-19	23-Jan-19
21-Jan-19	DGT SW1 616	2700	<5	16	8.43	30-Jan-19	04-Feb-19
30-Jan-19	DGT SW1 617	2700	<5	2.5	8.15	07-Feb-19	15-Feb-19

Heavy rainfall overnight and storm water run-off. No visible Oil&Grease during discharge.

EPA License Number: 4458

Licensee:

DEGREMONT PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

**POINT 2 Monthly Summary**

*Note: does not include any monitoring conducted prior to 31 March 2012.*

*Special Frequency 1 means <10 days prior to discharge; and*

*Special Frequency 2 means <5 days prior to discharge*

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Apr-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
May-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	No Discharges				20
	Manganese	milligrams per litre	Special Frequency 2					N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2					N/A
	Oil and Grease	milligrams per litre	Special Frequency 2					10
	Total suspended solids	milligrams per litre	Special Frequency 2					50
	Zinc	milligrams per litre	Special Frequency 2					N/A
	pH	pH	Special Frequency 2					6.5-8.5
Jun-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<4	<4	<4	20
	Manganese	milligrams per litre	Special Frequency 2	1	0.063	0.063	0.063	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2	1	5	5	5	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2	1	<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2	1	5	5	5	50
	Zinc	milligrams per litre	Special Frequency 2	1	0.0036	0.0036	0.0036	N/A
	pH	pH	Special Frequency 2	1	7.57	7.57	7.57	6.5-8.5
	Biochemical oxygen demand	milligrams per litre	Special Frequency 1					20
	Manganese	milligrams per litre	Special Frequency 2					N/A

Jul-12	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2	No Discharges				N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Aug-12	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Sep-12	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Oct-12	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Nov-12	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Dec-12	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jan-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Feb-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Mar-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Apr-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10

	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
May-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jun-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jul-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Aug-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20

Sep-13	<b>Manganese</b>	milligrams per litre	Special Frequency 2	No Discharges				N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Oct-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Nov-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Dec-13	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jan-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A

	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Feb-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Mar-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Apr-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
May-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A



Jun-14	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2	No Discharges				10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jul-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Aug-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Sep-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Oct-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Nov-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Dec-14	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jan-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Feb-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Mar-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50

	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Apr-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	1	3	3	3	20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2		0.108	0.108	0.108	N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2		5.4	5.4	5.4	N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2		16	16	16	50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2		0.006	0.006	0.006	N/A
	<b>pH</b>	pH	Special Frequency 2		7.39	7.39	7.39	6.5-8.5
May-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jun-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jul-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A

Aug-15	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2	No Discharges				N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Sep-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Oct-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Nov-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Dec-15	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Jan-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2		1.18	1.18	1.18	N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2		7.4	7.4	7.4	N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2		10	10	10	50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2		0.018	0.018	0.018	N/A
	<b>pH</b>	pH	Special Frequency 2		7.47	7.47	7.47	6.5-8.5
Feb-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Mar-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Apr-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
May-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10

	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jun-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	1	4	4	4	20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2		0.134	0.134	0.134	N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2		9.2	9.2	9.2	N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2		17	17	17	50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2		0.009	0.009	0.009	N/A
	<b>pH</b>	pH	Special Frequency 2		7.48	7.48	7.48	6.5-8.5
Jul-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Aug-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Sep-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20

Oct-16	<b>Manganese</b>	milligrams per litre	Special Frequency 2	No Discharges				N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Nov-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Dec-16	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jan-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Feb-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A

	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Mar-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2		1.59	1.59	1.59	N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2		9.8	9.8	9.8	N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2		28	28	28	50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2		0.017	0.017	0.017	N/A
	<b>pH</b>	pH	Special Frequency 2		7.7	7.7	7.7	6.5-8.5
Apr-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
May-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
Jun-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5
	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A



Jul-17	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2	No Discharges				10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Aug-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Sep-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Oct-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Nov-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Dec-17	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Jan-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Feb-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Mar-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Apr-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50

	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

May-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Jun-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Jul-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Aug-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1					20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A

Sep-18	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2	No Discharges				N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Oct-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Nov-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Dec-18	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

Jan-19	<b>Biochemical oxygen demand</b>	milligrams per litre	Special Frequency 1	No Discharges				20
	<b>Manganese</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Nitrogen (total)</b>	milligrams per litre	Special Frequency 2					N/A
	<b>Oil and Grease</b>	milligrams per litre	Special Frequency 2					10
	<b>Total suspended solids</b>	milligrams per litre	Special Frequency 2					50
	<b>Zinc</b>	milligrams per litre	Special Frequency 2					N/A
	<b>pH</b>	pH	Special Frequency 2					6.5-8.5

EPA License Number: 4458  
 Licensee:  
 DEGREMONT PTY LIMITED  
 PO BOX 6059  
 WETHERILL PARK NSW 2164  
 POINT 2    Obtained Data

*Note: does not include any monitoring conducted prior to 31 March 2012.*

Date Sampled	DGT Sample No.	Biochemical Oxygen Demand (mg/L)	Manganese (mg/L)	Nitrogen Total (mg/L)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	Zinc (mg/L)	pH (pH)	Date Obatined	Date Published
12-Jun-12	DGT SW2027	<4	0.063	5	<5	5	0.0036	7.57	20-Jun-12	5-Jul-12
29-Apr-15	DGT SW2 028	3	0.108	5.4	<5	16	0.006	7.39	8-May-15	8-May-15
07-Jan-16	DGT SW2 029	<2	1.18	7.4	<5	10	0.018	7.47	15-Jan-16	18-Jan-16
08-Jun-16	DGT SW2 030	4	0.134	9.2	<5	17	0.009	7.48	16-Jun-16	17-Jun-16
01-Mar-17	DGT SW2 031	<2	1.59	9.8	<5	28	0.017	7.7	9-Mar-17	9-Mar-17