Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name: SUEZ

Environmental Protection Licence Number: 12889

Facility Address: 1725 Elizabeth Drive
KEMPS CREEK, NSW 2178

Period: Feb-17

A copy of the full licence can be found on the POEO Public Register
http://www.epa.nsw.gov.au/prpoeoapp/

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZs knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
28/02/2017	1	1	Ammonia	Special frequency 1	1.92	1.92	1.92	1.92	mg/l	0.9	Y	Discharged to EDL sedimentation dam as per EPL condition P1.2.
28/02/2017	1	1	Biochemical oxygen demand	Special frequency 1	7	7	7	7	mg/l	NA	N	
28/02/2017	1	1	Condutivity	Special frequency 1	480	480	480	480	µS/cm	NA	N	
28/02/2017	1	1	Oil and Grease	Special frequency 1	<5	<5	<5	<5	mg/l	NA	N	
28/02/2017	1	1	pH	Special frequency 1	7..38	7..38	7..38	7..38	pH	6.5-8.5	N	
28/02/2017	1	1	Total organic carbon	Special frequency 1	21	21	21	21	mg/l	NA	N	
28/02/2017	1	1	Total suspended solids	Special frequency 1	33	33	33	33	mg/l	50	N	

Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name: SUEZ

Environmental Protection Licence Number: 12889

Facility Address: 1725 Elizabeth Drive
KEMPS CREEK, NSW 2178

Period: Feb-17

A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/prpoeoapp/

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZs knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments